


Secondary Heat – London's Zero Carbon Energy Resource

<http://www.london.gov.uk/priorities/environment/tackling-climate-change/energy-supply>



London's zero carbon energy resource – secondary heat



Secondary heat?

- Waste heat arising as a by-product of industrial and commercial activities
- Heat that exists naturally within the environment (air, ground, water)
- Variable temperature (usually 'low grade')
- Variable availability (seasonal, diurnal)
- Usually requires heat pumps (500KW +)
- higher inflow temp = higher COP of heat pump = better £ + CO₂
- Efficiently distributed via heat networks (at say 70°C)
- Increasing value as grid decarbonises and carbon budgets tighten

Why?


- Availability / viability of combustion fuels diminishes towards 2050
- Long-term viability of heat networks (not stranded assets 'post-gas')
- Greater energy self-sufficiency (London's 25% DE target)
- Zero NOx

Key objectives


- Quantify availability, cost and energy utilisation considerations
- Understanding issues of integration with heat networks and buildings
- Inform national and city policy and the 'market'
- Identify emerging project opportunities in London

Heat Recovery

Transformer



Metro Tunnel



Heat Pump COPs






Figure 2 - Heat pump COPs for four different heat output temperatures (500-1000kW scale heat pump).




Buro Happold


GREATER LONDON AUTHORITY

Key findings


- Most secondary heat sources need upgrading to higher temperatures to be useable in heat networks, this requires heat pumps.
- The minimum suitable operating temperature for heat networks is 55°C
- London's 2010 heat demand is 66TWh/yr - secondary heat sources can provide up to 71TWh/yr of heat at 70°C, of which:
 - 50 TWh/yr is attributed directly to the heat sources and
 - 21TWh/yr to the electricity required by heat pumps.
- Compared to conventional gas boiler heating
 - 12 TWh/yr of secondary heat can be considered 'cost effective'. This is equivalent to 18% of London's 2010 heat demand.
 - 56 TWh/yr of secondary heat can be considered 'CO2 effective'. This is equivalent to 56% of London's 2010 heat demand.

Impact on load duration curve of upgrading the fabric of a poor quality building (ie. residential E-rated)






Total available heat supply in each MSOA (kWh/m²)



Note: scale is non linear



This map is reproduced from Ordnance Survey material with the permission of Ordnance Survey on behalf of the Controller of Her Majesty's Stationery Office © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. (LA100032378)



Buro Happold



GREATERLONDONAUTHORITY

Contacts

Peter North
Senior Manager
Programme Delivery – Sustainable Energy
Greater London Authority

peter.north@london.gov.uk